

CRAFT STATE OFFICE BUILDING ROOF REPLACEMENT

Addendum 3

North Platte, Nebraska
1604

Wilkins Architecture Design Planning
2908 West 39th Street, Suite A
Kearney, Nebraska 68845
308-237-5787

Date Issued: June 1, 2016
Ad. Date: June 21, 2016

TO ALL BID DOCUMENT HOLDERS OF RECORD:

Acknowledge receipt of this addendum by inserting its number in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification. This Addendum forms a part of the BIDDING DOCUMENTS and modifies them as follows.

Addendum 3 – 1 Specification 07 5000 EPDM Roofing

Under 1.9.C.3. Add note to read; "Provide special Wind Speed Warranty up to 90 mph".
Under 2.2.B.2 delete in its entirety. Add note in its place to read; "INSULATION COVER BOARD: GYPSUM-BASE BOARD, ½ INCH THICK (OR AS THICK AS REQUIRED TO GET 30 YEAR WARRANTY AND WIND SPEED WARRANTY OF 90 MPH); COLD ADHESIVE ATTACHED."